



*Sediment had clogged the media, and so the City of Shoreline replaced the media that summer.*





*Unfortunately, less than two years later, towards the end of sampling, the Filterra were clogged again. This means media replacements have been needed every 2 to 3 years at this site.*



*We need to prioritize designing these treatment installations to minimize maintenance requirements. Because...*

**Bioretention can provide effective stormwater treatment, but only if the stormwater can get in.**



# Acknowledgements

- Brandi Lubliner – Ecology SAM Coordinator
- Fred Bergdolt – Project Liaison (WSDOT)
- KC Environmental Lab – Sampling & Analysis
  - Christopher Barnes (field lead)
- Pacific Rim Laboratories – PCB Analysis
- City of Shoreline – Site and Logistical Support
- Jenée Colton – Technical & Study Design Support